

Certificate of Inspection

Service Report

**VALID UNTIL THE LAST DAY OF THE MONTH - 12 MONTHS FROM THE DATE OF ISSUE
THIS CERTIFICATE CONFIRMS THAT THE EQUIPMENT LISTED BELOW HAS BEEN SERVICED
IN ACCORDANCE WITH BS5306: PART 3 - 2017 AND PASSED FIT FOR SERVICE.**



Trusted Fire Safety
Services | Supplies | Support

Company Name & Address:
West Moors Memorial Hall and Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Contact Name:
[Redacted]
Contact Number:
[Redacted]
Contact email:
[Redacted]

Service Agreement Number:
0711

(01202) 84 96 95
safe@thefirepoint.co.uk
Unit 3
Old Manor Farm Buildings
187 Leigh Road
Wimborne
BH21 2BT

| Unit Type | Ops SP/C | Basic Service | Not Maintained | Extended Service | Refilled | Service Exchange | Missing | Non Conforming | Failed | Condemn | New Commissioned |
|------------|----------|---------------|----------------|------------------|----------|------------------|---------|----------------|--------|---------|------------------|
| Water 9L | | | | | | | | | | | |
| Water 6L | | | | | | | | | | | |
| Water+ 6L | | | | | | | | | | | |
| Water+ 3L | | | | | | | | | | | |
| Foam 1L | | | | | | | | | | | |
| Foam 2L | | | | | | | | | | | |
| Foam 3L | | | | | | | | | | | |
| Foam 6L | | 6 | | | | | | | | | |
| Foam 9L | | | | | | | | | | | |
| CO2 - 2Kg | | 4 | | | | | | | | | |
| CO2 - 5Kg | | | | | | | | | | | |
| Powder 1Kg | | | | | | | | | | | |
| Powder 2Kg | | | | | | | | | | | |
| Powder 4Kg | | | | | | | | | | | |
| Powder 6Kg | | | | | | | | | | | |
| Powder 9Kg | | | | | | | | | | | |
| Wet Ch 2L | | | | | | | | | | | |
| Wet Ch 3L | | | | | | | | | | | |
| Wet Ch 6L | | | | | | | | | | | |
| Blanket | | 1 | | | | | | | | | |
| Totals | | 11 | | | | | | | | | |

| Additional | Size | Qty |
|------------------------|------|-----|
| Discharge Hose | | |
| Safety Clip/Pin | | |
| Cartridge 55g | | |
| Cartridge 75g | | |
| CO2 Hose & Horn | | |
| CO2 Horn | | |
| Anti-freeze Additive | | |
| Bracket | | |
| Appliance Disposal | | |
| Appliance Disposal (P) | | |
| Appliance Fitted | | |
| Base | | |
| Valve | | |
| Syphon Hose | | |
| Gauge | | |
| Stand S/D/T | | |
| Cabinet S/D/T | | |
| Trolley S/D/T | | |
| ID Sign | | |
| Action Notice | | |
| Safe Condition Sign | | |
| Mandatory Sign | | |

Additional Service Details - Recommendations - Variations

Fire Risk Assessment must be conducted for you to comply with fire safety law: The Regulatory Reform (Fire Safety Order) 2005. All of your legal obligations regarding fire safety in non-domestic operations can be found listed online, searching: "FSO 2005". Appropriate extinguisher provision relating to fire class in accordance with recommendations of British Standard BS5306-8:2012 is detailed overleaf. Reasons for deviating from such standards should also be documented as addenda to your Fire Risk Assessment.

I certify that the equipment has been serviced/supplied as detailed above.

Technician (Print): [Redacted]

Technician (Sign): [Redacted]

The work detailed above has been completed to my satisfaction, I am aware of any non-conformities and I accept Terms & Conditions overleaf.

Client (Print): [Redacted]

Client (Sign): [Redacted]

| | |
|-------------------|---------|
| Delivery | |
| Call Out | |
| Scheduled Service | ● |
| FRA Conducted? | Y ● N |
| FRA Seen? | Y ● N ● |

Non-Conformities

Site has outstanding work required to comply with BS5306-3:2017. Details listed adjacent.

Yes
Signed: [Redacted]

No
Signed: [Redacted]

Date: 03/05/2023



Guidance to Clients (BS5306-3:2017) Monthly Inspection

It is strongly recommended that in addition to this Annual Service, a regular inspection of all fire extinguishers is carried out by a competent person at intervals of at least monthly, to ensure that all appliances are in the proper position and have not been discharged or suffered damage, addressing User Responsibilities overleaf. QC01/A - issue 6 | 06/19

WARNING:
Misuse of fire extinguishers could cause damage to property and equipment, as well as injury

WASTE TRANSFER NOTE:
Registered Waste Carrier no: CBDL2272
Nature of waste is detailed above in 'Additional' section under 'Disposal'

REGULATORY
The Firepoint is a trading name of 3crossfire Ltd
Registered office: 256 Ashley Road, Parkstone, BH14 9BZ
Registered in England
Company No: 05677727
VAT Reg No: 8815062 21

Extinguisher Waste EWC: 16-05-05



Terms & Conditions - Information relative to your service

Maintenance

We strive to ensure that extinguishers will function to specification through servicing to current British Standards. However, we cannot accept responsibility for appliance failure between maintenance intervals due to misuse through human error, misjudgement, horseplay, misplacement, damage, negligence, component deterioration or insufficient training.

User Responsibility

It is recommended that regular (monthly) visual inspections of all portable fire extinguishers are conducted by the user or users representative. The frequency of the inspections should include that each fire extinguisher:

- Is located in the designated place on a secure and appropriate mounted or stand.
- Is unobstructed, visible with operating instructions facing outward.
- Has operating instructions that are clear and legible.
- Is not obviously damaged.
- Has a reading in the operable range or position of any pressure gauge or indicator, where fitted.
- Has seals and tamper indicators which are not missing or broken.

The user should contact The Firepoint for remedial work or corrective action where necessary.

Suitability

We endeavour to provide a working knowledge of appliance capability and suitability. However, we cannot accept responsibility for damage or injury caused by misuse through human error, misjudgement or horseplay, misplacement, damage, negligence, component deterioration or insufficient training.

Warranty

Five year warranties on new extinguishers supplied by The Firepoint are subject to equipment being continually maintained by The Firepoint. Inappropriate storage, use and maintenance by other service providers invalidates such warranties.

Inspection Codes

When an appliance has been serviced, the service label is marked with an inspection code which denotes the condition of the appliance and provides a history to each unit, detailing relevant works. Codes and their respective are detailed adjacent (Note: Discharge Testing is a mandatory British Standard requirement which applies to Water, Foam, Powder and Wet Chemical extinguishers and is conducted at five year intervals. Carbon Dioxide appliances are required to undergo Hydraulic Pressure Testing at ten year intervals. These tests are referred to as [Extended Service](#).)

You are not restricted by a fixed maintenance contract, your equipment is maintained under an Annual Rolling Maintenance Agreement which can be terminated at any time without notice by yourself. We will commit to contact you at the time of service interval to request a convenient booking time to perform the service. After three unsuccessful attempts to arrange a booking time, a letter of exoneration may be produced by The Firepoint to terminate the Annual Rolling Agreement on the grounds of agreement unviability, due to non contact.

Inspection Codes

BS – Basic Service
ES – Extended Service
R – Refilled
OH – Overhaul (10 year CO2 ES)
CT – Commission Test

British Standards

BS5306-3:2017 – Commissioning and Maintenance of portable fire extinguishers.

BS5306-8:2012 – Selection and Positioning of portable fire extinguishers in premises.

BS5306:9:2015 - Refill and recharging of fire extinguishers.

BS5306-8:2012 Fire Class and Extinguisher Provision Guide (*deviation from standard must be documented*).

Class A (Flammable Solids)

For each storey with a floor space less than and equal to 400m², two appliances should be provided to achieve a minimum combined fire rating of 26A, spaces larger should adopt 0.065 x floor space over 26A to achieve appropriate cover.

Maximum travel distance is 30 metres.

Class B (Flammable Liquids)

Specific guidance should be sought to calculate cover due to individual case variables. Volatile liquids are generally protected by powder extinguishers due to rapid flame knockdown capability.

Maximum travel distance is 10 metres.

Class C (Flammable Gases)

Specific guidance should be sought to calculate cover due to individual case requirements. Powder extinguishers are generally the chosen appliance for fighting Class C fires. However, consideration must be given to the ability to isolate supply prior to extinction. An explosion risk will be presented if the source of fuel cannot be isolated.

Maximum travel distance is 30 metres.
Health & Safety Risk Assessment should be conducted to mitigate internal presence.

Class D (Flammable Metals)

Specific guidance should be sought to calculate cover due to individual case requirements. Maximum travel distance is calculated by individual case variables.

Fire involving live electricity

Carbon Dioxide extinguishers are generally sourced as a clean agent to extinguish fires involving live electrical conductivity. Other appliances carrying the appropriate fire class symbol may be used, but to avoid any potential ambiguity or confusion, CO2 is recommended. Maximum travel distance is 10 metres.

Class F (Cooking Oils/Fats)

Extinguisher provision is based on a table provided within the British Standard document. A surface area between 0.24m² and 0.40m² will require 2 x 75F extinguishers. +0.40m² requires a fixed suppression system and -0.24m² based on Table.

Payment for Services | Supplies | Support

Any new equipment supplied by The Firepoint remains the property of The Firepoint until paid for in full. Payment terms are standard 30 days net, in accordance with The Late Payment of Commercial Debts Regulations (2013). Interest and recovery costs will be applied in accordance with these regulations as applicable.

The Firepoint is a trading name of 3crossfire Ltd. Reg'd in England. Reg No: 5677727, Reg Office: 256 Ashley Road, Parkstone, Poole, BH14 9BY.
QC01/A – issue 3 – 01/11/15



Certificate of Inspection
Portable Fire Extinguishers

VALID UNTIL THE LAST DAY OF THE MONTH - 12 MONTHS FROM THE DATE OF ISSUE
THIS CERTIFICATE CONFIRMS THAT THE EQUIPMENT DETAILED WITHIN THE SERVICE REPORT
HAS BEEN SERVICED IN ACCORDANCE WITH BS5306: PART 3 - 2017 AND PASSED FIT FOR SERVICE.



Company Name & Address:

West Moors Memorial Hall and Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Date Serviced:

03/05/2023

Technician Print:

[Redacted]

Technician Sign:

[Redacted]